

OHA

# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1				OFF		
2				OFF		
3				OFF		
4				OFF		
5				OFF		
6				OFF		
7				OFF		
8				OFF		
9				OFF		
10				OFF		
11				OFF		
12				OFF		
13				OFF		
14				OFF		
15				OFF		
16				OFF		
17	8.2		0.9		Y	
18						
19						
20						
21	8.2		0.6		Y	
22						
23						
24						
25						
26	8.2		0.7		Y	
27						
28						
29						
30						
31						
(No = N = Excursion)					Total N's	0

Well inspected daily. Samples collected when  
well is operating at time of inspection  
NR = Well not running during inspection

County: Wasco Agency: REGION 1

**Lone Pine Well**  
**ENTRY POINT**

**EP-B**  
**PWS ID 41-00869**  
**THE DALLES, CITY OF**

Sample period: May 2021

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

### Reference


#### Minimum Water Quality Parameter(s) as set by the State:

pH TBD

PO4 0.4 (Orthophosphate)

**Assessment Monitoring**

Print Name: Larry McCollum

Signature: 

Date & Phone: 07 Jun 2021; 541-298-2248 x 5000

Send to DWP within 10 days after the  
end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>