

OHA

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1				OFF		
2				OFF		
3				OFF		
4				OFF		
5				OFF		
6				OFF		
7	8.2		0.6		Y	
8				OFF		
9				OFF		
10				OFF		
11				OFF		
12				OFF		
13				OFF		
14				OFF		
15	8.0		0.5		Y	
16	8.1		0.8		Y	
17				OFF		
18				OFF		
19				OFF		
20				OFF		
21				OFF		
22				OFF		
23				OFF		
24				OFF		
25				OFF		
26				OFF		
27				OFF		
28				OFF		
29				OFF		
30				OFF		
31	8.2		0.5		Y	
(No = N = Excursion)					Total N's	0

County: Wasco Agency: REGION 1

Lone Pine Well
ENTRY POINT

EP-B
PWS ID 41-00869
THE DALLES, CITY OF

Sample period: July 2022

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by the State:**

pH 7.8

PO4 0.4 (Orthophosphate)

Print Name: Larry McCollum

Signature: 

Date & Phone: 4 Aug 2022; 541-298-2248 x 5000

Send to DWP within 10 days after the
end of the sampling period

Well inspected daily. Samples collected when
well is operating at time of inspection

NR = Well not running during inspection

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>