## Water Quality Parameter Monitoring Form

## **Lead & Copper Rule Corrosion Control**

Day	рН	Alk	Phos	Other	Y/N
1				NR	
2				NR	
3	8.1		0.5		Υ
4				NR	
5				NR	
6	8.1		0.5		Υ
7				NR	
8	8.1		0.5		Υ
9				NR	
10				NR	
11				NR	
12				NR	
13				NR	
14				NR	
15				NR	
16	8.2		0.6		Υ
17				NR	
18				NR	
19				NR	
20				NR	
21	8.2		0.5		Υ
22				NR	
23				NR	
24				NR	
25	8.2		0.5		Υ
26	8.2		0.2	)	N
27				NR	
28				NR	
29				NR	
30				NR	
31 Well Turned Off for the Season					
(No = N =	= Excurs	ursion) Total N's 1			

Well inspected daily. Samples collected when well is operating at time of inspection NR = Well not running during inspection

OFF = Well off for the season

<< Have minimums been met for this day?

County: Wasco

Agency: REGION 1

**Lone Pine Well ENTRY POINT** 

EP-B PWS ID 41-00869 THE DALLES, CITY OF

Sample period:

October 2022

Number of excursions during this month: \_\_\_\_1

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference					
Minimum Water Quality Parameter(s) as set by the State:					
pH 7.8					
PO4 0.4 (Orthophosphate)					

Print Name: Larry McCollum

Signature:

Date & Phone: 04 Nov 2022; 541-298-2248 x 5000

Send to DWP within 10 days after the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: http://healthoregon.org/dwp