

OHA

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

County: Wasco

Agency: REGION 1

**Lone Pine Well
ENTRY POINT****EP-B****PWS ID 41-00869
THE DALLES, CITY OF**

Sample period: November 2022

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference**Minimum Water Quality
Parameter(s) as set by the State:**pH 7.8PO4 0.4 (Orthophosphate)

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1	OFF FOR THE SEASON					
2	OFF FOR THE SEASON					
3	OFF FOR THE SEASON					
4	OFF FOR THE SEASON					
5	OFF FOR THE SEASON					
6	OFF FOR THE SEASON					
7	OFF FOR THE SEASON					
8	OFF FOR THE SEASON					
9	OFF FOR THE SEASON					
10	OFF FOR THE SEASON					
11	OFF FOR THE SEASON					
12	OFF FOR THE SEASON					
13	OFF FOR THE SEASON					
14	OFF FOR THE SEASON					
15	OFF FOR THE SEASON					
16	OFF FOR THE SEASON					
17	OFF FOR THE SEASON					
18	OFF FOR THE SEASON					
19	OFF FOR THE SEASON					
20	OFF FOR THE SEASON					
21	OFF FOR THE SEASON					
22	OFF FOR THE SEASON					
23	OFF FOR THE SEASON					
24	OFF FOR THE SEASON					
25	OFF FOR THE SEASON					
26	OFF FOR THE SEASON					
27	OFF FOR THE SEASON					
28*	Pump Maintenance					
29**	8.3		0.5			
30						
(No = N = Excursion)					Total N's	0

* Well repair on 28 Nov 22, pump to waste

** Well pumping to system from 29 Nov 22 for limited run testing of pump repair. Testing completed on 05 Dec 22.

Print Name: Larry McCollum

Signature: 

Date & Phone: 06 Dec 2022; 541-298-2248 x 5000

Send to DWP within 10 days after
the end of the sampling periodOHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>