

OHA

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N | << Have minimums been met for this day? |
|-----|--------------------|-----|------|-------|-----|--|
| 1 | | | | | | |
| 2 | 8.2 | | 0.5 | | Y | |
| 3 | | | | | | |
| 4 | | | | | | |
| 5 | OFF FOR THE SEASON | | | | | |
| 6 | OFF FOR THE SEASON | | | | | |
| 7 | OFF FOR THE SEASON | | | | | |
| 8 | OFF FOR THE SEASON | | | | | |
| 9 | OFF FOR THE SEASON | | | | | |
| 10 | OFF FOR THE SEASON | | | | | |
| 11 | OFF FOR THE SEASON | | | | | |
| 12 | OFF FOR THE SEASON | | | | | |
| 13 | OFF FOR THE SEASON | | | | | |
| 14 | OFF FOR THE SEASON | | | | | |
| 15 | OFF FOR THE SEASON | | | | | |
| 16 | OFF FOR THE SEASON | | | | | |
| 17 | OFF FOR THE SEASON | | | | | |
| 18 | OFF FOR THE SEASON | | | | | |
| 19 | OFF FOR THE SEASON | | | | | |
| 20 | OFF FOR THE SEASON | | | | | |
| 21 | OFF FOR THE SEASON | | | | | |
| 22 | OFF FOR THE SEASON | | | | | |
| 23 | OFF FOR THE SEASON | | | | | |
| 24 | OFF FOR THE SEASON | | | | | |
| 25 | OFF FOR THE SEASON | | | | | |
| 26 | OFF FOR THE SEASON | | | | | |
| 27 | OFF FOR THE SEASON | | | | | |
| 28 | OFF FOR THE SEASON | | | | | |
| 29 | OFF FOR THE SEASON | | | | | |
| 30 | OFF FOR THE SEASON | | | | | |
| 31 | OFF FOR THE SEASON | | | | | |

(No = N = Excursion)

Total N's

0

Well inspected daily. Samples collected when
well is operating at time of inspection

***The well was brought back on-line for about a week
for a maintenance function; then shut off again for the season

County: Wasco

Agency: REGION 1

Lone Pine Well
ENTRY POINT

EP-B**PWS ID 41-00869****THE DALLES, CITY OF**

Sample period: December 2022

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and
Distribution excursions are cumulative). An 'excursion' is any
day in which the water quality parameter(s) fall below the
minimum set by the State.

Reference


Minimum Water Quality
Parameter(s) as set by the State:

pH 7.8

PO4 0.4 (Orthophosphate)

Print Name: Larry McCollum

Signature:



Date & Phone: January 2023; 541-298-2248 x 5000

Send to DWP within 10 days after
the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>