

# OHA

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1	8.3		0.6		Y	
2	8.3		0.5		Y	
3						
4						
5						
6	8.3		0.6		Y	
7	8.3		0.6		Y	
8	8.3		0.7		Y	
9						
10						
11						
12	8.3		0.6		Y	
13	8.3		0.6		Y	
14						
15	8.3		0.6		Y	
16	8.3		0.7		Y	
17	8.3		0.6		Y	
18	8.3		0.5		Y	
19	8.4		0.5		Y	
20						
21	8.4		0.4		Y	
22						
23						
24	8.4		0.5		Y	
25						
26	8.3		0.4		Y	
27	8.3		0.5		Y	
28						
29						
30						
31						

(No = N = Excursion) **Total N's** 0

Well inspected daily. Samples collected when  
well is operating at time of inspection

County: Wasco Agency: REGION 1

**Lone Pine Well  
ENTRY POINT**

**EP-B  
PWS ID 41-00869  
THE DALLES, CITY OF**

Sample period: July 2023

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

### Reference

**Minimum Water Quality  
Parameter(s) as set by the State:**

pH 7.8

PO4 0.4 (Orthophosphate)

Print Name: Larry McCollum

Signature: 

Date & Phone: 11 Aug 2023; 541-298-2248 x 5000

Send to DWP within 10 days after the  
end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>