

OHA

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1						
2						
3						
4						
5						
6	8.2		0.7		Y	
7	8.3		0.5		Y	
8						
9						
10	7.7		0.5		N	
11						
12						
13						
14						
15						
16	8.2		0.6		Y	
17	8.2		0.5		Y	
18						
19						
20						
21	8.1		0.5		Y	
22						
23	8.1		0.5		Y	
24						
25	8.2		0.5		Y	
26						
27	8.2		0.5		Y	
28						
29	8.1		0.6		Y	
30						
					Total N's	1

(No = N = Excursion)

Well inspected daily. Samples collected when
well is operating at time of inspection

County: Wasco Agency: REGION 1

**Lone Pine Well
ENTRY POINT**

EP-B

**PWS ID 41-00869
THE DALLES, CITY OF**

Sample period: September 2023

Number of excursions during this month: 1

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by the State:**

pH 7.8

PO4 0.4 (Orthophosphate)

Print Name: Larry McCollum

Signature: 

Date & Phone: Oct 06, 2023; 541-298-2248 x 5000

Send to DWP within 10 days after
the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>