

# OHA

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1	8.2		0.7		Y	
2						
3						
4						
5						
6						
7	well only ran 4 days between the readings of the 1st and 17th; for short periods, <0.5 MG avg; during hours outside of routine inspections and readings					
8						
9						
10						
11						
12						
13						
14						
15						
16						
17	8.3		0.6		Y	
18						
19						
20						
21	8.1		0.5		Y	
22						
23						
24						
25						
26	8.1		0.5		Y	
27						
28						
29						
30						
31						
(No = N = Excursion)					Total N's	0

Well inspected daily. Samples collected when  
well is operating at time of inspection

County: Wasco Agency: REGION 1

**Lone Pine Well  
ENTRY POINT**

**EP-B  
PWS ID 41-00869  
THE DALLES, CITY OF**

Sample period: December 2023

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and  
Distribution excursions are cumulative). An 'excursion' is any  
day in which the water quality parameter(s) fall below the  
minimum set by the State.

### Reference

**Minimum Water Quality  
Parameter(s) as set by the State:**

pH 7.8

PO4 0.4 (Orthophosphate)

Print Name: Larry McCollum

Signature: 

Date & Phone: 02 January 2024; 541-298-2248 x 5010

Send to DWP within 10 days after  
the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>