

OHA

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

County: Wasco Agency: REGION 1

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1	8.2		0.6		Y	
2						
3						
4						
5						
6						
7						
8	8.1		0.6		Y	
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22	7.6		0.5		N	
23	Well off/not serving water					
24	Well off/not serving water					
25	Well on/serving water; NS					N
26	Well on/serving water; NS					N
27	Well off/not serving water					
28	Well off/not serving water					
29	Well on/serving water; NS					N
30	Well off/not serving water					
31	Well off/not serving water					
(No = N = Excursion)					Total N's	4

**Lone Pine Well
ENTRY POINT**

EP-B

**PWS ID 41-00869
THE DALLES, CITY OF**

March 2024

Sample period: **Amended**

Number of excursions during this month: 4

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by the State:**

pH

PO4 (Orthophosphate)

Print Name: Larry McCollum

Signature: 

Date & Phone: 17-Apr-24 541-298-2248 x 5010

Send to DWP within 10 days after the end of the sampling period

Well inspected daily. Samples collected when well is operating at time of inspection
NS = No Sample

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>