

OHA

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

County: Wasco Agency: REGION 1

**Lone Pine Well
ENTRY POINT**

EP-B

**PWS ID 41-00869
THE DALLES, CITY OF**

Sample period: July 2024

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1						Well offline for repairs. In service on July 8th, 2024.
2						
3						
4						
5						
6						
7						
8	7.9		0.9		y	
9	7.9		0.9		y	
10	7.8		0.6		y	
11	8.0		0.5		y	
12	8.0		0.5		y	
13	8.0		0.6		y	
14	8.0		0.8		y	
15	8.0		0.5		y	
16	8.0		0.6		y	
17	8.1		0.6		y	
18	8.0		0.6		y	
19	8.0		0.6		y	
20	8.0		0.5		y	
21	8.0		0.5		y	
22	8.0		0.7		y	
23	8.1		0.6		y	
24	8.0		0.5		y	
25	8.2		0.5		y	
26	8.1		0.5		y	
27	8.0		0.5		y	
28	8.0		0.5		y	
29	8.1		0.5		y	
30	8.0		0.6		y	
31	8.0		0.4		y	
(No = N = Excursion)					Total N's	0

Well inspected daily. Samples collected when well is operating at time of inspection


Reference

Minimum Water Quality Parameter(s) as set by the State:

pH

PO4 (Orthophosphate)

Print Name: Dave Anderson

Signature: 

Date & Phone: 6-Aug-2024; 541-506-2008

Send to DWP within 10 days after the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>