

# OHA

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1	W e l l					
2						
3						
4						
5						
6						
7	o f f					
8						
9						
10	f o r					
11						
12						
13	e l e c t r i c a l					
14						
15						
16						
17						
18						
19	r e p a i r s					
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						
(No = N = Excursion)					Total N's	0

County: Wasco Agency: REGION 1

**Lone Pine Well  
ENTRY POINT**

**EP-B**

**PWS ID 41-00869  
THE DALLES, CITY OF**

Sample period: December 2024

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

### Reference

**Minimum Water Quality  
Parameter(s) as set by the State:**

pH 7.8

PO4 0.4 (Orthophosphate)

Print Name: Tyler Mitchell

Signature: 

Date & Phone: 9-Jan-25 541-298-2248 x 5010

*Well inspected daily. Samples collected when  
well is operating at time of inspection*

Send to DWP within 10 days after  
the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>