

OHA

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1	8.1		0.5		Y	
2						
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14	8.3		0.5		Y	
15	8.2		0.5		Y	
16						
17	8.3		0.5		Y	
18						
19	8.2		0.5		Y	
20	Well off for the Season					
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						
31						

(No = N = Excursion) Total N's **0**

County: Wasco Agency: REGION 1

**Jordan Well
ENTRY POINT**

EP-C

**PWS ID 41-00869
THE DALLES, CITY OF**

Sample period: October 2021

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by the State:**

pH **7.8**

PO4 **0.4** (Orthophosphate)

Print Name: Larry McCollum

Signature: 

Date & Phone: Nov 2021; 541-298-2248 x 5000

Send to DWP within 10 days after
the end of the sampling period

Well inspected daily. Samples collected when
well is operating at time of inspection

NR = Well not running during inspection

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>