

OHA

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1				OFF		
2				OFF		
3				OFF		
4				OFF		
5				OFF		
6				OFF		
7				OFF		
8				OFF		
9				OFF		
10				OFF		
11				OFF		
12				OFF		
13				OFF		
14				OFF		
15				OFF		
16				OFF		
17				OFF		
18				OFF		
19				OFF		
20				OFF		
21				OFF		
22				OFF		
23				OFF		
24				OFF		
25				OFF		
26				OFF		
27				OFF		
28				OFF		

(No = N = Excursion) Total N's **0**

County: Wasco Agency: REGION 1

**Jordan Well
ENTRY POINT**

EP-C

PWS ID 41-00869

THE

DALLES, CITY OF

Sample period: February 2022

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by the State:**

pH **7.8**

PO4 **0.4** (Orthophosphate)

Print Name: Larry McCollum

Signature: 

Date & Phone: 03 Mar 2022; 541-298-2248 x 5000

Send to DWP within 10 days after the end of the
sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>