

OHA

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1	8.1		0.6		Y	
2				OFF		
3				OFF		
4				OFF		
5				OFF		
6				OFF		
7				OFF		
8				OFF		
9				OFF		
10				OFF		
11				OFF		
12	8.3		0.7		Y	
13				OFF		
14				OFF		
15	8.3		0.8		Y	
16				OFF		
17				OFF		
18				OFF		
19				OFF		
20	8.2		0.9		Y	
21				OFF		
22				OFF		
23				OFF		
24				OFF		
25				OFF		
26				OFF		
27				OFF		
28	8.2		0.6		Y	
29				OFF		
30				OFF		
31				OFF		
(No = N = Excursion)					Total N's	0

County: Wasco Agency: REGION 1

**Jordan Well
ENTRY POINT**

**EP-C
PWS ID 41-00869
THE DALLES, CITY OF**

Sample period: July 2022

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by the State:

pH 7.8

PO4 0.4 (Orthophosphate)

Print Name: Larry McCollum

Signature: 

Date & Phone: 4 Aug 2022; 541-298-2248 x 5000

Send to DWP within 10 days after the
end of the sampling period

*NR - Not running at time of maintenance inspection

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>