



## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7					
8	7.9		0.4		Y
9	8.0		0.5		Y
10					
11					
12					
13					
14					
15					
16					
17	7.9		0.5		Y
18					
19					
20					
21					
22					
23					
24	7.8		0.7		Y
25					
26					
27					
28					
29					
30					
31					
<b>Total N's</b>					<b>0</b>

<< Have minimums been met for this day?

County: Wasco Agency: REGION 1

**Jordan Well  
ENTRY POINT**

**EP-C  
PWS ID 41-00869  
THE DALLES, CITY OF**

Sample period: May 2024

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

**Reference**

**Minimum Water Quality  
Parameter(s) as set by the State:**

pH 7.8

PO4 0.4 (Orthophosphate)

Print Name: Larry McCollum

Signature:

Date & Phone: 06 June-24 541-298-2248 x 5010

(No = N = Excursion)

*Well inspected daily. Samples collected when well is operating at time of inspection*

Send to DWP within 10 days after the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>