

OHA

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N | << Have minimums been met for this day? |
|-----|-----|-----|------|-------|-----|--|
| 1 | 8.1 | | 0.7 | | y | |
| 2 | 8.0 | | 0.6 | | y | |
| 3 | 8.0 | | 0.7 | | y | |
| 4 | 8.0 | | 0.8 | | y | |
| 5 | 8.0 | | 0.6 | | y | |
| 6 | 8.1 | | 0.8 | | y | |
| 7 | 8.2 | | 0.7 | | y | |
| 8 | 8.0 | | 0.7 | | y | |
| 9 | 7.9 | | 0.6 | | y | |
| 10 | 8.0 | | 0.6 | | y | |
| 11 | 8.0 | | 0.7 | | y | |
| 12 | 8.0 | | 0.8 | | y | |
| 13 | 8.0 | | 0.8 | | y | |
| 14 | 8.0 | | 0.8 | | y | |
| 15 | 7.8 | | 0.8 | | y | |
| 16 | 7.8 | | 0.8 | | y | |
| 17 | 8.1 | | 0.5 | | y | |
| 18 | 7.8 | | 0.5 | | y | |
| 19 | 8.1 | | 0.6 | | y | |
| 20 | 8.0 | | 0.5 | | y | |
| 21 | 8.0 | | 0.7 | | y | |
| 22 | 8.2 | | 0.7 | | y | |
| 23 | 7.8 | | 0.8 | | y | |
| 24 | 8.1 | | 0.8 | | y | |
| 25 | 7.9 | | 0.9 | | y | |
| 26 | 8.1 | | 0.5 | | y | |
| 27 | 8.1 | | 0.7 | | y | |
| 28 | 8.1 | | 0.5 | | y | |
| 29 | 8.1 | | 0.6 | | y | |
| 30 | 8.2 | | 0.8 | | y | |
| 31 | 8.1 | | 0.5 | | y | |

County: Wasco Agency: REGION 1

**Jordan Well
ENTRY POINT**

EP-C

**PWS ID 41-00869
THE DALLES, CITY OF**

Sample period: July 2024

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by the State:**

pH

PO4 (Orthophosphate)

(No = N = Excursion) Total N's

Well inspected daily. Samples collected when well is operating at time of inspection

Print Name: Dave Anderson

Signature: 

Date & Phone: 6-Aug-2024; 541-506-2008

Send to DWP within 10 days after the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>