

# OHA

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

County: Wasco Agency: REGION 1

**Jordan Well  
ENTRY POINT**

**EP-C**

**PWS ID 41-00869  
THE DALLES, CITY OF**

Sample period: August 2024

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1	8.3		0.5		y	
2	8.1		0.7		y	
3	8.0		0.5		y	
4	8.2		0.5		y	
5	8.3		0.5		y	
6	8.2		0.5		y	
7	8.1		0.6		y	
8	8.1		0.5		y	
9	8.2		0.5		y	
10	8.2		0.5		y	
11	8.1		0.7		y	
12	8.1		0.5		y	
13	8.2		0.6		y	
14	8.0		0.5		y	
15	8.1		0.5		y	
16	8.1		0.7		y	
17	8.0		0.8		y	
18	8.1		0.5		y	
19	7.8		0.8		y	
20	8.1		0.5		y	
21	8.0		0.5		y	
22	8.1		0.7		y	
23	8.0		0.6		y	
24	8.0		0.7		y	
25	7.9		0.6		y	
26	8.0		0.7		y	
27	8.0		0.7		y	
28	8.1		0.5		y	
29	7.9		0.6		y	
30	8.0		0.5		y	
31	8.0		0.5		y	
(No = N = Excursion)					Total N's	0

*Reference*

**Minimum Water Quality  
Parameter(s) as set by the State:**

pH

PO4  (*Orthophosphate*)

Print Name: Dave Anderson

Signature: 

Date & Phone: 10-Sep-24 541-506-2008

*Well inspected daily. Samples collected when well is operating at time of inspection*

Send to DWP within 10 days after the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>