

OHA

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day						<< Have minimums been met for this day?
1						
2						
3						
4						
5	W					
6	e					
7	i					
8						
9						
10	o					
11	f					
12						
13	f					
14	o					
15	r					
16						
17	s					
18	e					
19	a					
20	s					
21	o					
22	n					
23						
24						
25						
26						
27	8.3		0.4			y
28	7.9		0.6			y
(No = N = Excursion)					Total N's	0

Well inspected daily. Samples collected when
well is operating at time of inspection

County: Wasco Agency: REGION 1

**Jordan Well
ENTRY POINT**

**EP-C
PWS ID 41-00869
THE DALLES, CITY OF**

Sample period: February 2025

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by the State:**

pH 7.8

PO4 0.4 (Orthophosphate)

Print Name: Tyler Mitchell

Signature: 

Date & Phone: 7-Mar-25 541-298-2248 x 5010

Send to DWP within 10 days after the end of the
sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>