

# OHA

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
11	8.1		0.5		Y	
12						
13						
14						
15						
16	8.0		0.6		Y	
17						
18	8.3		0.5		Y	
19						
20						
21						
22						
23	8.3		0.6		Y	
24						
25						
26						
27						
28						
29	8.2		0.5		Y	
30						

(No = N = Excursion) Total N's

Well inspected daily. Samples collected when  
well is operating at time of inspection

County: Wasco Agency: REGION 1

**Jordan Well  
ENTRY POINT**

**EP-C  
PWS ID 41-00869  
THE DALLES, CITY OF**

Sample period: April 2025

Number of excursions during this month:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

### Reference

**Minimum Water Quality  
Parameter(s) as set by the State:**

pH

PO4  (Orthophosphate)

Print Name: Tyler Mitchell

Signature: 

Date & Phone: 9-May-25 541-298-2248 x 5010

Send to DWP within 10 days after  
the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>