

OHA

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1	8.1		0.5		y	
2						
3	8.2		0.5		y	
4	8.1		0.5		y	
5	8.3		0.5		y	
6	8.1		0.4		y	
7	8.3		0.6		y	
8	8.3		0.5		y	
9	8.1		0.5		y	
10	8.2		0.6		y	
11	8.4		0.5		y	
12	8.2		0.5		y	
13	8.0		0.5		y	
14						
15	8.2		0.5		y	
16	8.2		0.5		y	
17	8.2		0.5		y	
18						
19	8.2		0.6		y	
20						
21						
22						
23						
24	8.2		0.6		y	
25	8.0		0.6		y	
26	8.3		0.7		y	
27						
28	8.0		0.6		y	
29	8.0		0.5		y	
30	8.3		0.5		y	

(No = N = Excursion) Total N's **0**

Well inspected daily. Samples collected when
well is operating at time of inspection

County: Wasco Agency: REGION 1

**Jordan Well
ENTRY POINT**

**EP-C
PWS ID 41-00869
THE DALLES, CITY OF**

Sample period: June 2025

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by the State:**

pH **7.8**

PO4 **0.4** (Orthophosphate)

Print Name: Tyler Mitchell

Signature: 

Date & Phone: 7/10/2025 541-298-2248 x 5010

Send to DWP within 10 days after
the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>