

OHA

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	8.1		0.6		Y
3					
4	8.4		0.5		Y
5					
6	8.0		0.6		Y
7					
8	8.0		0.5		Y
9					
10	8.0		0.5		Y
11	8.1		0.5		Y
12	8.0		0.5		Y
13	8.1		0.5		Y
14					
15	8.0		0.5		Y
16					
17					
18	8.1		0.6		Y
19					
20	8.0		0.5		Y
21					
22					
23					
24					
25	8.1		0.6		Y
26					
27	8.0		0.6		Y
28					
29	8.1		0.5		Y
30	8.2		0.5		Y
31					

(No = N = Excursion) **Total N's** 0

Well inspected daily. Samples collected when well is operating at time of inspection

County: Wasco Agency: REGION 1

**Jordan Well
ENTRY POINT**

**EP-C
PWS ID 41-00869
THE DALLES, CITY OF**

Sample period: August 2025

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by the State:**

pH 7.8

PO4 0.4 (Orthophosphate)

Print Name: Tyler Mitchell

Signature:

Date & Phone:

4-Sep-25

541-298-2248 Ext. 5010

Send to DWP within 10 days after
the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>