

OHA

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1	8.0		0.5		Y	
2						
3						
4						
5						
6						
7	8.0		0.5		Y	
8						
9						
10	8.1		0.5		Y	
11						
12						
13	8.1		0.6		Y	
14						
15	8.1		0.5		Y	
16						
17	8.1		0.5		Y	
18						
19						
20						
21						
22						
23	8.1		0.7		Y	
24						
25						
26						
27						
28						
29						
30						
31						

(No = N = Excursion)

Total N's

0

Well inspected daily. Samples collected when well is operating at time of inspection

County: Wasco Agency: REGION 1

Jordan Well
ENTRY POINT

EP-C

PWS ID 41-00869
THE DALLES, CITY OF

Sample period: October 2025

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by the State:**

pH PO4 (Orthophosphate)

Print Name: Tyler Mitchell

Signature: 

Date & Phone: 7-Nov-25 541-298-2248 x 5010

Send to DWP within 10 days after
the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>