

# OHA

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

County: Wasco Agency: REGION 1

**Jordan Well  
ENTRY POINT**

**EP-C  
PWS ID 41-00869  
THE DALLES, CITY OF**

Sample period: February 2026

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1	Well Off line For the Season					
2						
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						


**Reference**

**Minimum Water Quality Parameter(s) as set by the State:**

pH

PO4  (Orthophosphate)

(No = N = Excursion)  
Well inspected daily. Samples collected when well is operating at time of inspection

Print Name: Tyler Mitchell  
Signature:   
Date & Phone: 9-Mar-26 541-298-2248 x 5010

Send to DWP within 10 days after the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>