

OHA

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1						
2						
3	8.1		0.5		Y	
4	8.2		0.5		Y	
5	8.2		0.5		Y	
6	8.2		0.4		Y	
7	8.2		0.6		Y	
8						
9	8.2		0.6		Y	
10						
11	8.2		0.5		Y	
12						
13	8.1		0.6		Y	
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28	8.2		0.5		Y	
29						
30						
31						

(No = N = Excursion) Total N's **0**

County: Wasco

Agency: REGION 1

**Marks Well
ENTRY POINT**

EP-D

**PWS ID 41-00869
THE DALLES, CITY OF**

Sample period: October 2021

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by the State:**

pH **7.6**PO4 **0.4** (Orthophosphate)

Print Name: Larry McCollum

Signature:

Date & Phone: 08 Nov 2021; 541-298-2248 x 5000

Send to DWP within 10 days after
the end of the sampling period

Well inspected daily. Samples collected when
well is operating at time of inspection
NR = Well not running during inspection

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>