

# OHA

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

County: Wasco

Agency: REGION 1

**Marks Well**  
**ENTRY POINT**

**EP-D**

**PWS ID 41-00869**  
**THE DALLES, CITY OF**

Sample period: June 2022

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

### Reference

#### Minimum Water Quality Parameter(s) as set by the State:

pH 7.6PO4 0.4 (Orthophosphate)

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1				OFF		
2	8.2		0.5		Y	
3				OFF		
4				OFF		
5				OFF		
6				OFF		
7				OFF		
8				OFF		
9				OFF		
10				OFF		
11				OFF		
12				OFF		
13				OFF		
14				OFF		
15				OFF		
16				OFF		
17				OFF		
18				OFF		
19				OFF		
20				OFF		
21				OFF		
22	8.1		0.5		Y	
23				NR		
24				NR		
25				NR		
26	8.2		0.5		Y	
27				NR		
28	8.0		0.5		Y	
29				NR		
30				NR		
					<b>Total N's</b>	<b>0</b>

(No = N = Excursion)

Well inspected daily. Samples collected when  
well is operating at time of inspection  
NR = Well not running during inspection

Print Name: Larry McCollum

Signature: 

Date &amp; Phone: 01 Jul 2022; 541-298-2248 x 5000

Send to DWP within 10 days after  
the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>