

OHA

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1				OFF		
2				OFF		
3				OFF		
4				OFF		
5	8.1		0.7		Y	
6				OFF		
7				OFF		
8	8.0		0.6		Y	
9				OFF		
10				OFF		
11	8.0		0.5		Y	
12	7.6		0.7		Y	
13				OFF		
14	7.5		0.4		N	
15	8.6		0.6		Y	
16	8.2		0.6		Y	
17				OFF		
18				OFF		
19				OFF		
20				OFF		
21	8.1		0.5		Y	
22	8.2		0.5		Y	
23				OFF		
24	8.2		0.5		Y	
25	8.3		0.4		Y	
26	8.3		0.6		Y	
27	8.2		0.5		Y	
28	8.3		0.7		Y	
29	8.2		0.7		Y	
30	8.2		0.5		Y	
31	8.3		0.6		Y	

(No = N = Excursion) Total N's **1**

County: Wasco Agency: REGION 1

**Marks Well
ENTRY POINT**

**EP-D
PWS ID 41-00869
THE DALLES, CITY OF**

Sample period: July 2022

Number of excursions during this month: 1

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by the State:**

pH **7.6**

PO4 **0.4** (Orthophosphate)

Print Name: Larry McCollum

Signature: 

Date & Phone: 4 Aug 2022; 541-298-2248 x 5000

Send to DWP within 10 days after the
end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>