

# OHA

**Water Quality Parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1	8.2		0.6		Y	
2	8.2		0.7		Y	
3	8.3		0.8		Y	
4						
5	8.3		0.5		Y	
6	8.3		0.6		Y	
7	8.2		0.5		Y	
8	8.2		0.6		Y	
9	8.2		0.5		Y	
10	8.2		0.7		Y	
11						
12	8.3		0.6		Y	
13	8.4		0.7		Y	
14	8.3		0.5		Y	
15	8.3		0.7		Y	
16	8.3		0.7		Y	
17						
18	8.2		0.5		Y	
19	8.2		0.5		Y	
20	8.4		0.6		Y	
21	8.4		0.7		Y	
22	8.2		0.7		Y	
23	8.3		0.5		Y	
24	8.3		0.6		Y	
25	8.3		0.5		Y	
26	8.1		0.4		Y	
27	8.2		0.7		Y	
28						
29	8.0		0.6		Y	
30	8.2		0.7		Y	
31	8.2		0.6		Y	

(No = N = Excursion)

Total N's

0

*Well inspected daily. Samples collected when well is operating at time of inspection*

NR = Well not running during inspection

County: Wasco Agency: REGION 1

**Marks Well  
ENTRY POINT**

**EP-D**

**PWS ID 41-00869**

**THE DALLES, CITY OF**

Sample period: August 2022

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*


**Reference**

**Minimum Water Quality  
Parameter(s) as set by the State:**

pH 7.6

PO4 0.4 (Orthophosphate)

Print Name: Larry McCollum

Signature: 

Date & Phone: 06 Sep 2022; 541-298-2248 x 5000

Send to DWP within 10 days after  
the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>