

OHA

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N | << Have minimums been met for this day? |
|-----|-----|-----|------|-------|-----|---|
| 1 | 8.2 | | 0.5 | | Y | |
| 2 | 8.3 | | 0.5 | | Y | |
| 3 | 8.3 | | 0.4 | | Y | |
| 4 | | | NR | | | |
| 5 | 8.3 | | 0.8 | | Y | |
| 6 | 8.3 | | 0.4 | | Y | |
| 7 | 8.3 | | 0.7 | | Y | |
| 8 | 8.3 | | 0.5 | | Y | |
| 9 | 8.3 | | 0.7 | | Y | |
| 10 | | | NR | | | |
| 11 | 8.3 | | 0.5 | | Y | |
| 12 | | | | | | |
| 13 | | | NR | | | |
| 14 | 8.4 | | 0.4 | | Y | |
| 15 | | | NR | | | |
| 16 | 8.3 | | 0.5 | | Y | |
| 17 | | | NR | | | |
| 18 | | | NR | | | |
| 19 | 8.2 | | 0.5 | | Y | |
| 20 | 8.4 | | 0.4 | | Y | |
| 21 | | | NR | | | |
| 22 | 8.3 | | 0.6 | | Y | |
| 23 | | | NR | | | |
| 24 | | | NR | | | |
| 25 | 8.3 | | 0.6 | | Y | |
| 26 | | | NR | | | |
| 27 | | | NR | | | |
| 28 | 8.2 | | 0.5 | | Y | |
| 29 | | | NR | | | |
| 30 | | | NR | | | |

(No = N = Excursion)

Total N's

0

Well inspected daily. Samples collected when well is operating at time of inspection

NR = Well not running during inspection

County: Wasco Agency: REGION 1

Marks Well
ENTRY POINT

EP-D

PWS ID 41-00869

THE DALLES, CITY OF

Sample period: September 2022

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.


Reference

Minimum Water Quality
Parameter(s) as set by the State:

pH 7.6

PO4 0.4 (Orthophosphate)

Print Name: Larry McCollum

Signature: 

Date & Phone: 10 Oct 2022; 541-298-2248 x 5000

Send to DWP within 10 days after
the end of the sampling period