Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

<< Have

this day?

minimums

been met for

				-	COP
Day	рН	Alk	Phos	Other	Y/N
1				NR	
2				NR	
3				NR	
4				NR	
5				NR	
6	8.2		0.5		Υ
7				NR	
8				NR	
9				NR	
10				NR	
11	8.4		0.6		Υ
12				NR	
13				NR	
14				NR	
15				NR	
16				NR	
17				NR	
18				NR	
19	8.3		0.5		Υ
20				NR	
21				NR	
22				NR	
23				NR	
24				NR	
25				NR	
26				NR	
27	Well Off for the Season				
28	Well Off for the Season				
29	Well Off for the Season				
30	Well Off for the Season				
31	Well Off for the Season				
(No = N =	Excurs	ion)	To	tal N's	0

Well inspected daily. Samples collected when well is operating at time of inspection NR = Well not running during inspection

County: Wasco

Agency: REGION 1

Marks Well **ENTRY POINT**

EP-D

PWS ID 41-00869 THE DALLES, CITY OF

Sample period: October 2022

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Referen	ce	
	Minimum Water Quality Parameter(s) as set by the State:	
	pH 7.6	
	PO4 0.4 (Orthophosphate)	

Print Name: Larry McCollum

Signature:

Date & Phone: 04 Nov 2022; 541-298-2248 x 5000

Send to DWP within 10 days after the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp