

OHA

# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22	8.5		0.54		Y	
23	On standby, but not run to the system					
24	On standby, but not run to the system					
25	On standby, but not run to the system					
26	On standby, but not run to the system					
27	On standby, but not run to the system					
28						
29						
30						
31						

(No = N = Excursion) **Total N's** 0

Well inspected daily. Samples collected when well is operating at time of inspection

Well set up on stand-by to back up Wicks WTP due to freezing conditions limiting plant output

County: Wasco

Agency: REGION 1

**Marks Well**  
**ENTRY POINT**

**EP-D**  
**PWS ID 41-00869**  
**THE DALLES, CITY OF**

Sample period: December 2022

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

### Reference

**Minimum Water Quality**  
**Parameter(s) as set by the State:**

pH 7.6PO4 0.4 (Orthophosphate)

Print Name: Larry McCollum

Signature: 

Date &amp; Phone: 06 January 2023; 541-298-2248 x 5000

Send to DWP within 10 days after  
the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>