

OHA

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						
31						

Well turned off for the season

(No = N = Excursion)

Total N's 0

Well inspected daily. Samples collected when
well is operating at time of inspection

County: Wasco

Agency: REGION 1

Marks Well
ENTRY POINT

EP-D
PWS ID 41-00869
THE DALLES, CITY OF

Sample period: December 2023

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and
Distribution excursions are cumulative). An 'excursion' is any
day in which the water quality parameter(s) fall below the
minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by the State:**

pH 7.6

PO4 0.4 (Orthophosphate)

Print Name: Larry McCollum

Signature: 

Date & Phone: 02 January 2024; 541-298-2248 x 5010

Send to DWP within 10 days after
the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>