

OHA

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

County: Wasco Agency: REGION 1

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1	7.9		0.7		y	
2	7.8		0.9		y	
3	8.0		0.5		y	
4						
5						
6						
7	8.2		0.4		y	
8						
9						
10						
11	8.0		0.8		y	
12						
13	7.9		0.6		y	
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26	8.1		0.6		y	
27	8.0		0.6		y	
28	8.0		0.5		y	
29	7.9		0.7		y	
30						
(No = N = Excursion)					Total N's	0

**Marks Well
ENTRY POINT**

**EP-D
PWS ID 41-00869
THE DALLES, CITY OF**

Sample period: June 2024

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by the State:**

pH

PO4 (Orthophosphate)

Print Name: Larry McCollum

Signature: 

Date & Phone:

7/8/2024

541-298-2248 x 5010

Send to DWP within 10 days after
the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>

*Well inspected daily. Samples collected when
well is operating at time of inspection*