

# OHA

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1	7.8		0.8		y	
2	7.8		0.9		y	
3	7.9		0.6		y	
4	8.1		0.8		y	
5	8.0		0.7		y	
6	8.1		0.7		y	
7	8.0		0.6		y	
8	8.0		0.6		y	
9	8.1		0.7		y	
10	8.0		0.6		y	
11	8.1		0.7		y	
12	8.0		0.6		y	
13	7.7		0.6		y	
14	8.1		0.6		y	
15	7.9		0.5		y	
16	7.7		0.8		y	
17	8.1		0.7		y	
18	7.7		0.6		y	
19	7.7		0.6		y	
20	8.0		0.5		y	
21	8.0		0.6		y	
22	8.1		0.6		y	
23	8.0		0.6		y	
24	7.7		0.7		y	
25	7.7		0.6		y	
26	7.8		0.6		y	
27	7.7		0.6		y	
28	7.8		0.7		y	
29	7.6		0.6		y	
30	7.7		0.6		y	
(No = N = Excursion)					Total N's	0

Well inspected daily. Samples collected when  
well is operating at time of inspection

County: Wasco Agency: REGION 1

**Marks Well  
ENTRY POINT**

**EP-D  
PWS ID 41-00869  
THE DALLES, CITY OF**

Sample period: September 2024

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

### Reference

**Minimum Water Quality  
Parameter(s) as set by the State:**

pH 7.6

PO4 0.4 (Orthophosphate)

Print Name: Tyler Mitchell

Signature: 

Date & Phone: 1-Oct-24 541-298-2248 x 5010

Send to DWP within 10 days after  
the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>