

OHA

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						
31						

(No = N = Excursion) Total N's **0**

County: Wasco Agency: REGION 1

**Marks Well
ENTRY POINT**

**EP-D
PWS ID 41-00869
THE DALLES, CITY OF**

Sample period: January 2025

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by the State:**

pH **7.6**

PO₄ **0.4** (Orthophosphate)

Print Name: Tyler Mitchell

Signature: 

Date & Phone:

4-Feb-25

541-298-2248 x 5010

Well inspected daily. Samples collected when well is operating at time of inspection

Send to DWP within 10 days after the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>