

OHA

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N | << Have minimums been met for this day? |
|-----|-------------------------------------|-----|------|-------|-----|--|
| 1 | Well off for the Season | | | | | |
| 2 | | | | | | |
| 3 | | | | | | |
| 4 | | | | | | |
| 5 | | | | | | |
| 6 | | | | | | |
| 7 | | | | | | |
| 8 | | | | | | |
| 9 | | | | | | |
| 10 | | | | | | |
| 11 | | | | | | |
| 12 | | | | | | |
| 13 | | | | | | |
| 14 | | | | | | |
| 15 | | | | | | |
| 16 | | | | | | |
| 17 | | | | | | |
| 18 | | | | | | |
| 19 | | | | | | |
| 20 | | | | | | |
| 21 | | | | | | |
| 22 | | | | | | |
| 23 | | | | | | |
| 24 | | | | | | |
| 25 | | | | | | |
| 26 | | | | | | |
| 27 | | | | | | |
| 28 | | | | | | |
| 29 | | | | | | |
| 30 | | | | | | |
| 31 | | | | | | |

(No = N = Excursion)

Total N's

0

Well inspected daily. Samples collected when
well is operating at time of inspection

County: Wasco

Agency: REGION 1

**Marks Well
ENTRY POINT**

**EP-D
PWS ID 41-00869
THE DALLES, CITY OF**

Sample period: March 2025

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by the State:**

pH 7.6

PO4 0.4 (Orthophosphate)

Print Name: Tyler Mitchell

Signature:

Date & Phone:

2-Apr-25

541-298-2248 x 5010

Send to DWP within 10 days after the
end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>