

OHA

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1	OFF FOR THE SEASON					
2	OFF FOR THE SEASON					
3	OFF FOR THE SEASON					
4	OFF FOR THE SEASON					
5	OFF FOR THE SEASON					
6	OFF FOR THE SEASON					
7	OFF FOR THE SEASON					
8	OFF FOR THE SEASON					
9	OFF FOR THE SEASON					
10	OFF FOR THE SEASON					
11	OFF FOR THE SEASON					
12	OFF FOR THE SEASON					
13	OFF FOR THE SEASON					
14	OFF FOR THE SEASON					
15	OFF FOR THE SEASON					
16	OFF FOR THE SEASON					
17	OFF FOR THE SEASON					
18	OFF FOR THE SEASON					
19	OFF FOR THE SEASON					
20	OFF FOR THE SEASON					
21	OFF FOR THE SEASON					
22						
23						
24						
25	8.2		0.7		Y	
26	8.4		0.7		Y	
27						
28						
29						
30						

(No = N = Excursion)

Total N's **0**

*Well inspected daily. Samples collected when
well is operating at time of inspection*

County: Wasco

Agency: REGION 1

**Marks Well
ENTRY POINT**

EP-D

**PWS ID 41-00869
THE DALLES, CITY OF**

Sample period: April 2025

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by the State:**

pH **7.6**

PO4 **0.4** (Orthophosphate)

Print Name: Tyler Mitchell

Signature: 

Date & Phone:

9-May-25

541-298-2248 x 5010

Send to DWP within 10 days after
the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>