

# OHA

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

County: Wasco Agency: REGION 1

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1	Well of for the Season					
2						
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						
(No = N = Excursion)					Total N's	0

**Marks Well  
ENTRY POINT**

**EP-D  
PWS ID 41-00869  
THE DALLES, CITY OF**

Sample period: November 2025

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

### Reference

**Minimum Water Quality  
Parameter(s) as set by the State:**

pH

PO4  (Orthophosphate)

Print Name: Tyler Mitchell

Signature: 

Date & Phone: 5-Dec-25 541-298-2248 x 5010

Send to DWP within 10 days after  
the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>

*Well inspected daily. Samples collected when  
well is operating at time of inspection*