



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

County: Wasco Agency: REGION 1

ID#	Sample Location	pH	PO4	Y/N	<< Has sample met the minimums?
I-1	3643 Columbia View Dr (1)	8.0	0.5	Y	
C-5	3455 Royal Crest Dr (1)	8.0	0.6	Y	
G-2	1825 E. 9th (1)	7.3	0.5	Y	
S-2	Riverview & 13th St (1)	7.3	0.4	Y	
G-11	211 Webber (1)	7.7	0.4	Y	
G-9	1112 Cherry Heights (1)	7.8	0.4	Y	
G-5	1900 W 6th (2)	7.8	0.4	Y	
G-12	200 E 12th (2)	7.3	0.5	Y	
G-4	623 E 11th (2)	7.3	0.4	Y	
E-3	1304 Quinton (2)	7.3	0.4	Y	
V-2	18th & Morton (2)	7.3	0.4	Y	
C-12	445 E Knoll Dr (2)	8.0	0.6	Y	
S-3	1800 block Liberty Wy (2)	7.2	0.4	Y	
W-1	2405 Wright St (3)	7.3	0.5	Y	
G-7	2350 Garrison (3)	7.9	0.4	Y	
G-14	3600 block Crates Way (3)	7.8	0.4	Y	
S-7	1301 E 19th (3)	7.3	0.4	Y	
E-1	2119 E 12th (3)	7.3	0.5	Y	
I-6	341 Lone Pine Dr (3)	8.0	0.5	Y	
V-1	2101 E. 19th (4)	7.3	0.5	Y	
G-13	3600 Block Klindt Dr (4)	7.8	0.4	Y	
G-8	905 W 6th (4)	7.8	0.4	Y	
G-1	1006 E. 2nd (4)	8.0	0.6	Y	
S-1	Crnr 12th & Morton	8.0	0.6	Y	
S-4	Behind Sorosis Park	7.4	0.4	Y	
G-10	1017 W 9th	7.6	0.5	Y	
Total N's				0/26	

(No = N = Excursion)

(1) Sampled 06 Jul 21

(2) Sampled 12 Jul 21

(3) sampled 19 Jul 21

(4) Sampled 26 Jul 21

DISTRIBUTION

PWS ID 41-00869

THE DALLES, CITY OF

Sample period: July 2021

Sample frequency: 3-years

Distribution Samples required: 7

Number of excursions during
this Sample Period: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by the State:**

pH 7.0

PO4 0.4 (Orthophosphate)

Print Name: Larry McCollum

Signature: _____

Date & Phone: 02 Sep 21 541-298-2248 x 5000

Send to DWP within 10 days after
the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>