



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

ID#	Location	pH	PO4	Y/N	<< Has sample met the minimums?
I-1	3643 Columbia View Dr (1)	8.0	0.6	y	
C-5	3455 Royal Crest Dr (1)	8.0	0.5	y	
G-2	1825 E. 9th (1)	7.7	0.6	y	
S-2	Riverview & 13th St (1)	7.6	0.5	y	
G-11	211 Webber (1)	7.8	0.5	y	
G-9	1112 Cherry Heights (1)	7.9	0.5	y	
G-5	1900 W 6th (2)	7.8	0.5	y	
G-12	200 E 12th (2)	7.5	0.5	y	
G-4	623 E 11th (2)	7.5	0.5	y	
E-3	1304 Quinton (2)	7.5	0.6	y	
V-2	18th & Morton (2)	7.6	0.5	y	
C-12	445 E Knoll Dr (2)	8.2	0.5	y	
S-3	1800 block Liberty Wy (2)	7.7	0.6	y	
W-1	2405 Wright St (3)	7.5	0.5	y	
G-7	2350 Garrison (3)	7.5	0.5	y	
G-14	3600 block Crates Way (3)	7.7	0.7	y	
S-7	1301 E 19th (3)	7.5	0.5	y	
E-1	2119 E 12th (3)	7.6	0.4	y	
I-6	341 Lone Pine Dr (3)	8.0	0.3	n	
V-1	2101 E. 19th (4)	7.1	0.5	y	
G-13	3600 Block Klindt Dr (4)	7.8	0.6	y	
G-8	905 W 6th (4)	7.8	0.6	y	
G-1	1006 E. 2nd (4)	7.7	0.6	y	
S-1	Crrr 12th & Morton (4)	7.4	0.5	y	
S-4	Behind Soroosis Park (4)	7.1	0.5	y	
G-10	1017 W 9th (4)	7.8	0.6	y	

(No = N = Excursion)

(1) Sampled 24-Sep-24

(2) Sampled 3-Sep-24

Total N's

1

(3) sampled 9-Sep-24

(4) Sampled 17-Sep-24

County: Wasco Agency: REGION 1

DISTRIBUTION

PWS ID 41-00869

THE DALLES, CITY OF

Sample period: Sep 2024

Sample frequency: 3-years

Distribution Samples required: 7

Number of excursions during

this Sample Period: 1

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality
Parameter(s) as set by the State:

pH 7.0

PO4 0.4 (Orthophosphate)

Print Name: Tyler Mitchell

Signature: 

Date & Phone: 02-Oct-24 541-298-2248 x 5010

Send to DWP within 10 days after
the end of the sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp>