

# OHA

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	<< Have minimums been met for this day?
1	8.0		0.5		y	
2	8.1		0.6		y	
3	8.0		0.6		y	
4	8.0		0.5		y	
5	8.0		0.6		y	
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						

Well in Standard by

County: Wasco Agency: REGION 1

**Riverside**

**ENTRY**

**POINT**

**EP-E**

**PWS ID 41-00869**

**THE DALLES, CITY OF**

Sample period: November 2025

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*


**Reference**

**Minimum Water Quality  
Parameter(s) as set by the State:**

pH

PO4  (Orthophosphate)

Print Name: Tyler Mitchell

Signature: 

Date & Phone: 5-Dec-25 541-298-2248 x 5010

(No = N = Excursion) Total N's

*Well inspected daily. Samples collected when well is operating at time of inspection*

Send to DWP within 10 days after the end of the sampling period