

Water Quality Parameter Monitoring Form - DISTRIBUTION

Lead & Copper Rule - Corrosion Control

PWS ID: OR4100878
 System Name: City of Tigard
 Sample Period: 2nd Quarter 2023
 Sampling Frequency: Every three years
 Distribution Samples Required: Two sets of seven each


Date	Sample Location	pH	Alkalinity (mg/L)	Sample met minimums? Y/N
6/12/2023	#3 - 7866 SW King Fisher Way	7.72	26	Y
6/12/2023	#63 - 13389 SW Shakespeare	7.86	26	Y
6/12/2023	#58 - 14255 SW High Torr Dr. (6")	7.82	24	Y
6/12/2023	#56 - 13465 SW Nachotta	7.85	25	Y
6/12/2023	#47 - 13789 SW Rosy Court	8.00	25	Y
6/12/2023	#41 - 14184 SW Startdust Lane	8.02	24	Y
6/12/2023	#24 - 12000 SW 116th Avenue	7.91	26	Y
6/13/2023	#3 - 7866 SW King Fisher Way	7.93	27	Y
6/13/2023	#63 - 13389 SW Shakespeare	7.81	26	Y
6/13/2023	#58 - 14255 SW High Torr Dr. (6")	7.77	25	Y
6/13/2023	#56 - 13465 SW Nachotta	7.85	25	Y
6/13/2023	#47 - 13789 SW Rosy Court	7.94	25	Y
6/13/2023	#41 - 14184 SW Startdust Lane	7.84	24	Y
6/13/2023	#24 - 12000 SW 116th Avenue	7.87	26	Y
Number of excursions during this sample period =				0

(Number of locations when any WQP was less than the minimum)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sampling period.

For OHA use only	
Minimum Water Quality Parameters as set by	
pH	7.2
Alkalinity	15 mg/L
Other	

Print Name: Jennifer Joe

Signature: 

Date: 7/18/2023

Send to dwp.dmce@odsoha.oregon.gov within 10 days after end of sampling period.
 OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350
 Phone: (971) 673-0405 | Website: <http://healthoregon.org/dwp/>