



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31					
30					
29					
28	8.61				
27	7.78				
26	7.9				
25	7.66				
24	7.4				
23	7.47				
22	7.46				
21	7.45				
20	7.44				
19	7.45				
18	7.63				
17	7.67				
16	7.86				
15	7.37				
14	7.72				
13	7.45				
12	7.8				
11	7.78				
10	7.6				
9	7.78				
8	7.9				
7	8.02				
6	8.16				
5	8.34				
4	8.75				
3	8.02				
2	8.34				
1	8.62				

<<Have minimums been met for this day?

ENTRY POINT

A

PWS ID 4100886

CLOVERDALE WATER DISTRICT

Sample period: February 2021
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
 Is system in compliance? Y / N

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Larry Chitwood

Signature: [Signature]

Date: 3-1-21

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period
 Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381