



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31	8.8				Y
30	8.34				Y
29	8.34				Y
28	8.44				Y
27	8.58				Y
26	8.67				Y
25	8.9				Y
24	9.03				Y
23	8.83				Y
22	8.69				Y
21	8.73				Y
20	8.7				Y
19	8.71				Y
18	8.66				Y
17	8.47				Y
16	8.44				Y
15	8.06				Y
14	7.35				Y
13	7.31				Y
12	7.42				Y
11	7.5				Y
10	7.37				Y
9	7.79				Y
8	8.4				Y
7	8.61				Y
6	8.62				Y
5	8.63				Y
4	8.69				Y
3	8.72				Y
2	8.61				Y
1	8.63				Y

<<Have minimums been met for this day?

ENTRY POINT
A
PWS ID 4100886
CLOVERDALE WATER DISTRICT

Sample period: March 2021
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
 Is system in compliance? Y N

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Larry Chitwood
 Signature: [Signature]
 Date: 4-2-2021

(No = N = Excursion) Total N's 0