



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
31	7.90				Y
30	7.90				Y
29	7.43				Y
28	7.91				Y
27	7.99				Y
26	8.01				Y
25	8.04				Y
24	8.06				Y
23	8.12				Y
22	8.61				Y
21	8.13				Y
20	7.95				Y
19	8.30				Y
18	8.25				Y
17	8.52				Y
16	8.07				Y
15	7.73				Y
14	7.54				Y
13	7.47				Y
12	7.25				Y
11	7.41				Y
10	7.29				Y
9	7.5				Y
8	7.34				Y
7	7.30				Y
6	7.32				Y
5	7.93				Y
4	7.93				Y
3	7.67				Y
2	7.52				Y
1	7.81				Y

<<Have minimums been met for this day?

**ENTRY POINT**

**A**

**PWS ID 4100886**

**CLOVERDALE WATER DISTRICT**

Sample period: JUN 2021

Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)  
 Is system in compliance? **Y / N**

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Leif Bledsoe

Signature: Leif Bledsoe

Date: 6-30-2021

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period

Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381