



Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31	8.24				Y
30	8.28				Y
29	7.90				Y
28	7.52				Y
27	7.43				Y
26	8.49				Y
25	8.32				Y
24	8.34				Y
23	8.33				Y
22	8.42				Y
21	8.8				Y
20	8.7				Y
19	8.49				Y
18	8.48				Y
17	8.30				Y
16	8.34				Y
15	8.02				Y
14	7.41				Y
13	7.29				Y
12	7.46				Y
11	7.38				Y
10	7.23				Y
9	7.38				Y
8	7.42				Y
7	7.54				Y
6	7.49				Y
5	7.46				Y
4	7.43				Y
3	7.42				Y
2	7.29				Y
1	7.69				Y

<<Have minimums been met for this day?

ENTRY POINT
A

PWS ID 4100886

CLOVERDALE WATER DISTRICT

Sample period: July/2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
Is system in compliance? Y/N

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Larry Chitwood
Signature: [Signature]
Date: 8-2-21

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period
Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381