



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31	8.2				Y
30	8.16				Y
29	7.95				Y
28	8.26				Y
27	8.22				Y
26	8.21				Y
25	7.92				Y
24	7.92				Y
23	7.95				Y
22	8.01				Y
21	8.11				Y
20	8.18				Y
19	7.97				Y
18	7.83				Y
17	7.71				Y
16	7.79				Y
15	7.55				Y
14	7.32				Y
13	7.49				Y
12	7.55				Y
11	7.62				Y
10	7.75				Y
9	7.75				Y
8	7.36				Y
7	7.49				Y
6	7.68				Y
5	7.75				Y
4	8.39				Y
3	7.58				Y
2	8.7				Y
1	8.24				Y

<<Have minimums been met for this day?

ENTRY POINT

A

PWS ID 4100886

CLOVERDALE WATER DISTRICT

Sample period: AUGUST/2021
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
 Is system in compliance? Y / N

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Larry Chitwood

Signature: [Signature]

Date: 8-1-21

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period
 Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381