



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31					
30	8.06				Y
29	8.56				Y
28	8.22				Y
27	8.25				Y
26	8.13				Y
25	7.99				Y
24	8.9				Y
23	7.81				Y
22	7.77				Y
21	7.62				Y
20	7.92				Y
19	7.32				Y
18	7.8				Y
17	7.31				Y
16	7.32				Y
15	7.25				Y
14	8.12				Y
13	8.02				Y
12	8.07				Y
11	8.01				Y
10	8.07				Y
9	8.27				Y
8	8.18				Y
7	7.92				Y
6	8.26				Y
5	8.34				Y
4	8.35				Y
3	7.99				Y
2	7.92				Y
1	7.88				Y

<<Have minimums been met for this day?

**ENTRY POINT
A**

PWS ID 4100886

CLOVERDALE WATER DISTRICT

Sample period: September/2021
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
 Is system in compliance? Y / N

Reference _____

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Larry Chitwood

Signature: [Signature]

Date: 9-30-21

(No = N = Excursion) Total N's 0