



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
31	7.77				Y
30	7.56				Y
29	7.59				Y
28	7.31				Y
27	7.55				Y
26	7.35				Y
25	7.55				Y
24	7.63				Y
23	7.68				Y
22	7.69				Y
21	7.67				Y
20	7.73				Y
19	7.77				Y
18	7.88				Y
17	8.04				Y
16	8.43				Y
15	8.29				Y
14	8.11				Y
13	8				Y
12	7.98				Y
11	8.4				Y
10	8.44				Y
9	8.5				Y
8	8.59				Y
7	8.3				Y
6	8.56				Y
5	8.46				Y
4	8.59				Y
3	8.52				Y
2	8.5				Y
1	8.53				Y

<<Have minimums been met for this day?

**ENTRY POINT**  
**A**  
**PWS ID 4100886**  
**CLOVERDALE WATER DISTRICT**

Sample period: November / 2021  
 Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)  
 Is system in compliance? Y / N

Reference

Minimum Water Quality Parameters as set by State:  
 pH 7.2

Print Name: Larry Chitwood  
 Signature: [Signature]  
 Date: 11-3-21

(No = N = Excursion) Total N's 0