



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31					
30	7.49				Y
29	7.32				Y
28	7.74				Y
27	8				Y
26	7.81				Y
25	7.77				Y
24	7.69				Y
23	7.75				Y
22	7.92				Y
21	7.55				Y
20	7.52				Y
19	7.59				Y
18	7.54				Y
17	8.12				Y
16	8.27				Y
15	8.03				Y
14	7.7				Y
13	7.39				Y
12	7.43				Y
11	7.55				Y
10	7.43				Y
9	7.35				Y
8	7.32				Y
7	7.43				Y
6	7.44				Y
5	7.55				Y
4	7.78				Y
3	7.29				Y
2	7.77				Y
1	7.75				Y

<<Have minimums been met for this day?

ENTRY POINT
A
PWS ID 4100886
CLOVERDALE WATER DISTRICT

Sample period: November 2021
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
 Is system in compliance? Y / N

Reference

Minimum Water Quality Parameters as set by State:
 pH 7.2

Print Name: Larry Chitwood
 Signature: [Signature]
 Date: 11-2-2021

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period
 Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381