



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
31	7.8				Y
30	7.8				Y
29	7.5				Y
28	7.3				Y
27	7.9				Y
26	7.8				Y
25	7.8				Y
24	8				Y
23	7.8				Y
22	7.7				Y
21	7.7				Y
20	7.6				Y
19	7.7				Y
18	7.8				Y
17	7.6				Y
16	7.7				Y
15	7.7				Y
14	7.7				Y
13	7.8				Y
12	7.3				Y
11	8.1				Y
10	8				Y
9	8.1				Y
8	7.9				Y
7	7.8				Y
6	7.8				Y
5	7.9				Y
4	7.3				Y
3	7.3				Y
2	7.3				Y
1	7.4				Y

<<Have minimums been met for this day?

**ENTRY POINT  
A**

**PWS ID 4100886**

**CLOVERDALE WATER DISTRICT**

Sample period: December/2021  
Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)  
 Is system in compliance? Y/N

Reference \_\_\_\_\_

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Larry Chittwood  
 Signature: \_\_\_\_\_  
 Date: 1-7-21

(No = N = Excursion) Total N's 0